

Rouleaux blancs Uponor AquaPEX

Renseignements sur le projet

Nom du poste :	Lieu :
Ingénieur :	Date de soumission:
Entrepreneur :	Présentée par:
Représentant du fabricant :	Approuvé par :

Données techniques

Material	PEX
Temp/pressure ratings	73 °F (23 °C) at 160 psi (11 bar)
	180 °F (82 °C) at 100 psi (6.9 bar)
	200 °F (93 °C) at 80 psi (5.5 bar)

Informations sur le produit et utilisation de l'application

Uponor AquaPEX White is an Engel-method, PEX-a pipe designed for hot and cold domestic potable water distribution and residential fire safety as well as radiant heating/cooling and hydronic piping systems containing no ferrous corrodible components or where ferrous components are isolated from the piping. The product features a black print string that displays the brand name, manufacturing method, and various codes, standards, and listings.

Note: Temperature and pressure ratings stated are hydrostatic ratings. For domestic hot-water (DHW) and DHW recirculation installations, operating conditions should not exceed 140°F (60°C) at 80 psi (5.5 bar) in accordance with ASTM F2023. For additional information regarding application-specific temperature and pressure ratings, refer to the Uponor PEX Piping Systems Design and Installation Manual.



Nom de la pièce	Numéro de pièce	Les codes	Normes	Annonces
Rouleaux blancs Uponor AquaPEX	All	IMC UPC IBC IRC NBC of Canada IPC UFGS NPC of Canada UMC NSPC	ASTM F1960 ASTM E119 UL 263 ASTM F876 ASTM E84 ASTM F2023 ASTM E814 ULC S115 ASTM F877 CSA B137.5 ULC S102.2 CSA B214 ULC S101	IAPMO-ES ICC-ES-PMG CCMC PPI TR-4 CSA UL U.P.Code cQAIus P321 HUD MR 1269 BMEC

L'installation	Applications connexes
Use ProPEX® fittings for 3/8" through 3" pipe. 1 Refer to the ProPEX Connections Instructional Guide, Uponor Piping Pocket Guide, Plumbing Design Assistance Manual (PDAM), Complete Design Assistance Manual (CDAM), Hydronic Piping Design Assistance Manual (HPDAM) or AquaSAFE™ Residential Fire Sprinkler Installation Guide for more information.	PEX-a Plumbing Systems Radiant Heating and Cooling Systems Hydronic Piping Systems

Notes de bas de page	Coordonnées de la personne-ressource
-	Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008 Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517