

Valves à bille d'alimentation et de retour pour collecteur

Renseignements sur le projet

Nom du poste :	Lieu :
Ingénieur :	Date de soumission:
Entrepreneur :	Présentée par:
Représentant du fabricant :	Approuvé par :

Données techniques

Material	Brass
End type 1	ISO 228-G 1-1/4"
End type 2	ISO 228-G 1-1/4"
Temp/pressure ratings	73 °F (23 °C) at 160 psi (11 bar) 180 °F (82 °C) at 100 psi (6.9 bar) 200 °F (93 °C) at 80 psi (5.5 bar)
Prop 65 label required?	Yes

Informations sur le produit et utilisation de l'application

Uponor Manifold Supply and Return Ball Valves are R32 male by R32 female that fit directly on Uponor TruFLOW™ and Engineered Polymer (EP) Heating Manifolds. A2631250 and A2631251 come standard with a temperature gauge for easy visual check of supply temperatures. A2631250 also features a built-in filter ball which has isolation within the valve to facilitate cleaning of the filter.



Nom de la pièce	Numéro de pièce	Cv	Cv Through	Weight per UOM [kg/UOM]
Manifold Supply and Return Ball Valves with Filter and Temperature Gauge, set of 2	A2631250	15.6	38.5	2.495
Manifold Supply and Return Ball Valves with Temperature Gauges, set of 2	A2631251	38.5	38.5	2.019
Manifold Supply and Return Ball Valves, set of 2	A2631252	23.8	23.8	1.304

Nom de la pièce	Numéro de pièce	Les codes	Normes	Annonces
Valves à bille d'alimentation et de retour pour collecteur	All	-	R32: ISO 228-G 1 1/4" ASTM F877	-

L'installation

Thread the supply ball valve into the supply manifold and the return ball valve into the return manifold. Close the valve and unscrew the filter inspection lid to clean the filter ball (if applicable). Remove the clip that holds the filter and remove the filter. Remove debris from the filter and reinsert the filter in its seat. Tighten the lid and re-open the valve. Use silicone oil as required. Accessories: Temperature Gauge with Well, replacement part (A2610120).

Applications connexes

Radiant Heating and Cooling Systems

Remarques :

Connection:
R32
Cv Supply 15.6
Cv Return 38.5

Connection:
R32
Cv Supply 38.5
Cv Return 38.5

Connection:
R32
Cv Supply 23.8
Cv Return 23.8

Notes de bas de page

Coordonnées de la personne-ressource

-	Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008	Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517
---	---	---