Trousses d'essai de pression en laiton pour collecteur

Renseignements sur le projet

Nom du poste :	Lieu :
Ingénieur :	Date de soumission:
Entrepreneur :	Présentée par:
Représentant du fabricant :	Approuvé par :

Données techniques

Material	Brass
Subcomponent Material	Chrome Steel
Prop 65 label required?	Yes



Informations sur le produit et utilisation de l'application

The Uponor Brass Manifold Pressure Test Kit for is for use with 1¼" Uponor TruFLOW™ Manifolds. Each kit contains an R32 X ¾" manifold bushing, an R32 solid brass plug, and a ¾" brass nipple and pressure gauge assembly (100 psi). A Schraeder valve is also included.

L'installation

Thread one end of the ¾" brass nipple into the pressure gauge assembly and the other end into the R32 x ¾" brass plug. Thread the R32 x ¾" brass plug into the inlet of the supply or return manifold. Thread the R32 solid brass plug into the inlet of the opposite manifold. Pressure the system with air to 60 psi. The system should maintain this pressure for at least 24 hours. For additional information, refer to the Uponor Radiant Installation Handbook.

Applications connexes

Radiant Heating and Cooling Systems

Notes de bas de page

-

Coordonnées de la personne-ressource

Uponor Inc.
5925 148th Street West
Apple Valley, MN 55124
T 800.321.4739
F 952.891.2008

Uponor Ltd.
6510 Kennedy Road
Mississauga, ON L5T 2X4
T 888.594.7726
F 800.638.9517

© 2024 Uponor Amérique du Nord. Tous droits réservés