

Régulateurs Smatrix Pulse avec modules de communication

Renseignements sur le projet

| | |
|-----------------------------|---------------------|
| Nom du poste : | Lieu : |
| Ingénieur : | Date de soumission: |
| Entrepreneur : | Présentée par: |
| Représentant du fabricant : | Approuvé par : |

Données techniques


| | |
|---|--------|
| Operating temperature min. [°F] | 32 °f |
| Operating temperature max. [°F] | 113 °f |
| Ambient temperature min. [F] | -4 °f |
| Ambient temperature max. [F] | 158 °f |
| Ambient humidity non-condensing max [%] | 85 |
| Prop 65 label required? | Yes |

Informations sur le produit et utilisation de l'application

Smatrix Pulse provides precise wireless control of radiant floor heating as well as forced-air heating and cooling systems in one solution that connects to a smart home assistant and can also be controlled remotely via the Smatrix Pulse App.

The Smatrix Pulse Controller (X-265) with Communication Module (R-208) connects up to six (6) thermostats and eight (8) actuators. The controller operates the actuators, which, in turn, affect the flow of the supply water to change the indoor temperature using information transmitted from the registered thermostats and system parameters.

Note: For the Smatrix Pulse Transformer (A3850050) and Communication Module (A3801208) technical data, refer to that individual product submittal or the Smatrix Pulse Installation and Operation Manual.



D: TRANSFORMER LENGTH AFTER INSTALLATION

| Nom de la pièce | Numéro de pièce | A [inch] | B [inch] | C [inch] | D [inch] | E [inch] | Operating voltage AC [VAC] | Relay rating at 24VAC [A] | Weight per UOM [lbs/UOM] |
|--|-----------------|----------|----------|----------|----------|----------|----------------------------|---------------------------|--------------------------|
| Smatrix Pulse Controller (X-265) with Communication Module (R-208) | A380265C | 13.268 | 4.331 | 2.165 | 3.307 | 4.331 | 115 | 2.5 | 3.9 |

| Nom de la pièce | Numéro de pièce | Les codes | Normes | Annonces |
|---|-----------------|-----------|---|----------------------------------|
| Régulateurs Smatrix Pulse avec modules de communication | A380265C | - | FCC KDB996369 D04 IC RSS-210 ICC RSS-Gen FCC 47 CFR Part 15 | IC 7664A-SM4NA1 FCC ID V9MSM4NA1 |

| L'installation | Applications connexes |
|--|--|
| Refer to the Smatrix Pulse Installation and Operation Manual for installation information. | Radiant Hydronic Heating & Cooling Tools & Accessories |

| Notes de bas de page | Coordonnées de la personne-ressource | | |
|---|--|---|---|
| - | <table border="0"> <tr> <td>Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008</td> <td>Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517</td> </tr> </table> | Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008 | Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517 |
| Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008 | Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517 | | |