# Coudes pour collecteur de chauffage en EP

## Renseignements sur le projet

| | |
|---|---|
| Nom du poste : | Lieu : |
| Ingénieur : | Date de soumission: |
| Entrepreneur : | Présentée par: |
| Représentant du fabricant : | Approuvé par : |

## Données techniques

| | |
|---|---|
| Temp/pressure ratings | 140 °F (60 °C) at 87 psi (6 bar)<br>158 °F (70 °C) at 72 psi (5 bar)<br>176 °F (80 °C) at 58 psi (4 bar)<br>194 °F (90 °C) at 44 psi (3 bar) |
| Prop 65 label required? | Yes |



## Informations sur le produit et utilisation de l'application

The Engineered Polymer (EP) Heating Manifold Elbow (A2670090) enables connections to supply and return piping from above or below. Two elbows feature different lengths to accommodate tube spacing for the supply and return lines on a EP Heating Manifold for use in hydronic radiant heating and cooling systems. Use only propylene glycol in radiant systems with EP Heating Manifolds; never use ethylene glycol.

| | Nom de la pièce | Numéro de pièce | Weight per UOM [kg/UOM] |
|---|---|---|---|
| ✔ | EP Heating Manifold Elbow, set of 2 | A2670090 | 0.154 |

## L'installation

Hand-tighten the elbow to the supply and return on the manifold. For additional information, refer to the instruction sheet. Note: Use only propylene glycol in radiant heating and cooling systems with EP Heating Manifolds; never use ethylene glycol. Refer to the EP Heating Manifold Installation Guide for a complete chemicals list.

## Applications connexes

Radiant Heating and Cooling Systems

Permafrost Protection Systems

Turf Conditioning Systems

## Notes de bas de page

-

## Coordonnées de la personne-ressource


Uponor Inc.
5925 148th Street West
Apple Valley, MN 55124
T 800.321.4739
F 952.891.2008

Uponor Ltd.
6510 Kennedy Road
Mississauga, ON L5T 2X4
T 888.594.7726
F 800.638.9517


© 2024 Uponor Amérique du Nord. Tous droits réservés