

Date of valid edition

2022-03-09

No./Revision:

4039-28

Date of first issue:

1995-05-30

Name and address of certificate holder

Conformity marks covered by the certificate:

Uponor Infra Oy
P.O. Box 21
FI-15561 NASTOLA



Information regarding the certificate holder/manufacturer

Contact person Jaana Hallikas	Telephone +358 20 129 211	
	E-mail jaana.hallikas@uponor.com	
Manufacturer	Place of manufacture Nastola, Finland	

Product covered by the certificate

Type of product Plastic piping systems for non-pressure underground drainage and sewerage. Structured-wall piping systems of unplasticized poly(vinyl chloride) (PVC-U), polypropylene (PP) and polyethylene (PE).	Standard/Normative document EN 13476	Specific rules SBC 13476
Specification of product Structured-wall piping systems of polypropylene (PP) and polyethylene (PE) according to annex 1. Approved raw materials and sealings according to annex 2 (confidential). Inspection of production: VTT-S-05300-06, SP FX112026.		

The certificate holder above is hereby given permission to use the INSTA-CERT mark on or in connection with products, which fulfil the requirements of the standard or the normative document specified above (what is said in this document about INSTA-CERT mark will also be valid for marks defined in relevant SBC). The certificate is valid on the condition that the certificate holder complies with "General rules for certification by partners of INSTA-CERT" (GRC) and the specific rules applying to certification of products of the type mentioned. The certificate holder is obliged to indemnify INSTA-CERT partners of any claim for damages or any other expenses to which partners may become liable as a result of injuries caused by a product manufactured or sold by the certificate holder. This also applies to defective or faulty products.

Unless terminated, the certificate will be automatically extended for one year at a time. The certificate will be re-issued with a new "date of valid edition" only if the content and/or conditions of the certificate have been changed. Termination may take place to the end of a year subject to three months' notice on the part of the certificate holder and the certification body. Information of valid certificates is available on INSTA-CERT homepage, www.insta-cert.net.

The certificate is not transferable.

MEMBER OF INSTA-CERT:
INSPECTA CERTIFIOINTI OY

Maija Vanttaja, Managing Director

Certificate No. **4039-28**

Date 2022-03-09

Certificate holder

Uponor Infra Oy
P.O. Box 21
FI-15561 NASTOLA

UPONOR SEWER SYSTEM

Trade name	Uponor IQ and Uponor IQ Blue pipes	Uponor Ultra Double	Duplex	Ultra Classic pipes With and without sockets	Ultra Rib 2
Material	PP	PP	PP	PP	PP
Pipes					
Colour					
- outer layer	black	brown	reddish brown or black	brown or black	
- inner layer	grey or white	grey or white	grey or green	brown, grey or white	
Wall construction type	B	B	B	A1	
Application area	UD				
Ring stiffness Diameters, OD; mm	SN 8 200, 250 and 315 (group sizes 1-2)	SN 8 200, 250 and 315 (group sizes 1-2)	SN 8 160, 200, 250 and 315 (group sizes 1- 2)	SN 4 and SN 8 110,160 and 200 (group size 1)	
				SN 8 250 and 315 (group size 2)	
Application area	U				
Ring stiffness	SN 8	SN 8	SN 8	SN 8	
Diameters /OD; mm		450 and 560 (group sizes 2-3)	400 (group size 2)	400 (group size 2)	
Diameters /ID, mm	400 and 500 (group size 2)				
Bends, branches and other fittings					
Wall construction type					B
Colour					reddish brown
Ring stiffness					SN 8
Application area Diameters /OD, mm (group sizes 1-2)					UD 160, 200, 250 and 315
Application area Diameters /OD, mm (group size 2)					U 400, 450 and 500
Designation of production place	1				