

Uponor Water Service Pipe for IPC and IRC Jurisdictions Information Sheet

For jurisdictions that adopt the International Plumbing Code (IPC) and/or the International Residential Code (IRC), Uponor AquaPEX® White is approved for water service pipe applications.


Note that the local authority having jurisdiction (AHJ) may have additional requirements beyond the IPC and/or IRC, and they have the final approval decision. So, it is important to know the local codes and AHJ requirements in your area.

Table 605.3 Water Service Pipe

Material	Standard
Cross-linked polyethylene (PEX) plastic pipe and tubing	ASTM F876; AWWA C904; CSA B137.5

Figure 1: Line Excerpted from Table 605.3

Note: Remember that model codes may be amended, and local ordinances may impact the specific code language, so refer to the specific language enforced in your jurisdiction.



UPONOR AquaPEX® PEX 5106 3/4IN SDR9

For IPC/IRC Jurisdictions Where Inspector States Pipe Must Meet AWWA C904

The IPC states in Section 605.3 that water service pipe shall conform to NSF 61 as well as **one** of the standards listed in Table 605.3. Uponor AquaPEX White conforms to NSF 61 along with ASTM F876 **and** CSA B137.5, thus holding two of the standards listed in Table 605.3. Therefore, it is approved for use in water service piping applications. Note that for the IRC, the reference table is Table P2906.4 in Section P2906.4 and has identical requirements.

Uponor Products for Water Service Pipes

For jurisdictions that follow the IPC and/or IRC, use Uponor AquaPEX White pipe in ½" to 2" sizes. These piping products comply with the requirements of Section 605.3 in the IPC and Section P2906.4 in the IRC. They meet ASTM F876 **and** CSA B137.5 — two of the standards listed in the respective tables.

► Learn how Uponor can help drive your business forward at uponor.com.

Uponor Inc.
5925 148th Street West
Apple Valley, MN 55124 USA
T 800.321.4739
F 952.891.2008

Uponor Ltd.
6510 Kennedy Road
Mississauga, ON L5T 2X4
T 888.594.7726
F 800.638.9517

Uponor
Moving > Forward