

Manufacturer Declaration

Testing of the retention capacity of a precipitation-water treatment system

Company: GF Piping Systems Ltd.
Ebnatstrasse 111
8201 Schaffhausen / Switzerland

Production site: Uponor Infra AB
Industrivägen 11
51332 Fristad / Sweden

Product: Filter Chamber 1000-160

Material: PE

Application: Storm water management

Summary of laboratory tests, performed at IKT Gelsenkirchen, Germany:

Matter retention for a connected surface of 1,000 m² (full-flow treatment)

Fine-particled filterable mineral matter AFS (TSS)

Overall result **88.06%**

Fine-particled filterable mineral matter AFS63 (TSS63)

Overall result **70.48%**

Category as per DWA-A 102-2 **Category III**

Mineral-oil hydrocarbons (MOH) as per DIBt

Overall result **71.54%**



Signed by:

09F8CB8B7C16433...

DocuSigned by:

D7BB14A1F92B46C...

Name: Rickard Granath
Position: Product Manager Stormwise
Date: 13.12.2024

Patric Haas
Approvals Manager Infrastructure
13.12.2024