


## Uponor Smatrix Wave I-167




## Interface Software Upgrade

### Safety instructions

	<b>Caution! (Notification type)</b> Do not remove the microSD card while the interface is powered on.
	<b>Caution! (Notification type)</b> Make sure the same microSD card is inserted in the interface when the upgrade is finished. Otherwise your installation might stop working.
	<b>Caution! (Notification type)</b> To not damage the SD-card, use "Safely Remove Hardware and Eject Media" when removing the SD-card from the computer.
	<b>Note (Notification type)</b> Finish the preparation steps before upgrading.
	<b>Note (Notification type)</b> Make sure to have a microSD adapter or reader handy. It is needed for to transfer the software to the the microSD card.

### Preparation










If a pre-loaded SD-card is supplied by Uponor, the preparation steps is unnecessary.

To prepare the upgrade process:

1. Go to the local Uponor website.
2. Locate the upgrade page for Uponor Smatrix Wave, and check if there are any new upgrades available.
3. Download the latest version of the software.

# Upgrading



To upgrade the software on the interface:

1. Power off the interface.
2. Eject the microSD card from the interface.  
If a pre-loaded SD-card is supplied by Uponor, skip step 3 and use the supplied card from step 4.
3. Copy the file (upgrade.bin) to the microSD card. Overwrite any existing upgrade.bin-files.  
**NOTE!** Use "Safely Remove Hardware and Eject Media".
4. Insert the microSD card into the interface again.
5. Power on the interface.
6. Go to the **SD card** menu, **Main menu > System settings > SD card**.
7. Press **Update with SD-card**.
8. Confirm that system settings can be changed during the process.  
The display will restart before starting the update.
9. Wait until the counter in interface has reached 100%, the interface has restarted and the home screen is shown again.
10. The software update is now complete.

## Uponor GmbH

Industriestraße 56,  
D-97437 Hassfurt, Germany

1091820 11\_2017  
Production: Uponor / MRY

Uponor reserves the right to make changes, without prior notification, to the specification of incorporated components in line with its policy of continuous improvement and development.



[www.uponor.com](http://www.uponor.com)